

SECTION 21 0719
FIRE SUPPRESSION PIPING INSULATION

PART 2 PRODUCTS

1.01 REGULATORY REQUIREMENTS

- A. Surface Burning Characteristics: Flame spread index/Smoke developed index of 25/50, maximum, when tested in accordance with ASTM E84 or UL 723.

END OF SECTION 21 0719

